



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Larc School
1089 Creek Road
Bellmawr, NJ 08031

Results of Lead Analysis

Sample ID:	Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
U120951	Field Blank	07/06/2022 06:35	07/11/2022 14:19	<2.00	15.5	SM3113B
U120952	Kit Sink Large	07/06/2022 06:37	07/11/2022 14:25	5.69	15.5	SM3113B
U120953	Kit Sink Small	07/06/2022 06:38	07/11/2022 14:32	18.86	15.5	SM3113B
U120954	Staff Lounge BR	07/06/2022 06:40	07/11/2022 14:38	8.59	15.5	SM3113B
U120955	Staff Lounge Kitchen	07/06/2022 06:38	07/11/2022 14:45	6.58	15.5	SM3113B
U120956	Cafe BR Womens Room	07/06/2022 06:41	07/11/2022 14:51	10.04	15.5	SM3113B
U120957	Cafe BR Mens Room	07/06/2022 06:42	07/11/2022 14:58	9.62	15.5	SM3113B
U120958	Office Sink Main Office	07/06/2022 06:43	07/11/2022 15:05	2.06	15.5	SM3113B
U120959	Office Sink BR - Main Office	07/06/2022 06:44	07/11/2022 15:11	8.05	15.5	SM3113B
U120960	Nurse Office BR Sink	07/06/2022 06:45	07/11/2022 15:18	6.91	15.5	SM3113B
U120961	Room 18 Sink	07/06/2022 07:32	07/11/2022 15:38	<2.00	15.5	SM3113B
U120962	Room 18 BR Sink	07/06/2022 07:33	07/11/2022 15:58	<2.00	15.5	SM3113B
U120963	Room 19 Sink	07/06/2022 07:34	07/11/2022 16:04	4.86	15.5	SM3113B
U120964	Room 20 Sink	07/06/2022 07:35	07/11/2022 16:11	<2.00	15.5	SM3113B
U120965	Room 20 BR Sink	07/06/2022 07:36	07/12/2022 10:09	6.59	15.5	SM3113B
U120966	Room 21 Sink	07/06/2022 07:37	07/12/2022 10:28	<2.00	15.5	SM3113B
U120967	Room 21 BR Sink	07/06/2022 07:39	07/12/2022 10:35	2.03	15.5	SM3113B
U120968	Room 17 Sink	07/06/2022 07:28	07/12/2022 10:41	2.70	15.5	SM3113B
U120969	Room 17 BR Sink	07/06/2022 07:29	07/12/2022 10:48	9.69	15.5	SM3113B
U120970	Room 16 Sink	07/06/2022 07:26	07/12/2022 10:54	5.39	15.5	SM3113B
U120971	Room 15 Sink	07/06/2022 07:25	07/12/2022 11:01	7.76	15.5	SM3113B
U120972	Room 14 Sink	07/06/2022 07:23	07/12/2022 11:07	8.28	15.5	SM3113B
U120973	Room 14 BR	07/06/2022 07:40	07/12/2022 11:27	7.99	15.5	SM3113B
U120974	New Nurse Office	07/06/2022 07:30	07/12/2022 11:34	5.18	15.5	SM3113B
U120975	New Kitchen Sink 1	07/06/2022 07:18	07/12/2022 11:40	3.88	15.5	SM3113B
U120976	New Kitchen Sink 2	07/06/2022 07:19	07/12/2022 11:47	<2.00	15.5	SM3113B
U120977	Room 13 Sink	07/06/2022 07:15	07/12/2022 11:53	5.07	15.5	SM3113B
U120978	Room 12 Sink	07/06/2022 07:14	07/12/2022 12:00	8.77	15.5	SM3113B
U120979	Room 11 Sink	07/06/2022 07:13	07/12/2022 12:07	5.05	15.5	SM3113B
U120980	Room 10 Sink	07/06/2022 07:11	07/12/2022 12:13	3.74	15.5	SM3113B
U120981	Room 9 Sink	07/06/2022 07:10	07/12/2022 12:20	5.94	15.5	SM3113B
U120982	Room 8 Sink	07/06/2022 07:01	07/12/2022 12:27	12.78	15.5	SM3113B
U120983	Room 7 Sink	07/06/2022 07:02	07/12/2022 12:46	3.53	15.5	SM3113B
U120984	Room 6 Sink	07/06/2022 06:59	07/12/2022 13:06	2.70	15.5	SM3113B
U120985	Room 5 Sink	07/06/2022 07:00	07/12/2022 13:13	2.98	15.5	SM3113B
U120986	Room 4 Sink	07/06/2022 06:55	07/12/2022 13:19	6.23	15.5	SM3113B
U120987	Room 3 Sink	07/06/2022 06:56	07/12/2022 13:25	5.65	15.5	SM3113B

Units - ug/L = ppb



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Larc School
1089 Creek Road
Bellmawr, NJ 08031

Results of Lead Analysis

Sample ID:	Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
U120988	Room 2 Sink	07/06/2022 06:51	07/12/2022 13:32	5.29	15.5	SM3113B
U120989	Room 1 Sink	07/06/2022 06:49	07/12/2022 13:38	6.64	15.5	SM3113B
U120990	Room 1 BR Sink	07/06/2022 06:50	07/12/2022 13:45	6.50	15.5	SM3113B
U120991	Room 2 BR Sink	07/06/2022 06:52	07/12/2022 14:05	15.36	15.5	SM3113B
U120992	Room 3 BR Sink	07/06/2022 06:57	07/12/2022 14:11	10.47	15.5	SM3113B
U120993	Room 4 BR Sink	07/06/2022 06:54	07/12/2022 14:18	9.70	15.5	SM3113B
U120994	Comp Room BR	07/06/2022 06:47	07/12/2022 14:24	2.49	15.5	SM3113B
U120995	Hall BR Small	07/06/2022 06:46	07/12/2022 14:31	9.32	15.5	SM3113B
U120996	Boys Room Sink	07/06/2022 07:07	07/12/2022 14:38	13.45	15.5	SM3113B
U120997	Boys Room Sink	07/06/2022 07:08	07/12/2022 14:44	6.81	15.5	SM3113B
U120998	Boys Room Sink	07/06/2022 07:09	07/12/2022 14:51	6.82	15.5	SM3113B
U120999	Girls Room Sink	07/06/2022 07:04	07/12/2022 14:58	6.37	15.5	SM3113B
U121000	Girls Room Sink	07/06/2022 07:09	07/12/2022 15:04	3.85	15.5	SM3113B
U121001	Girls Room Sink	07/06/2022 07:06	07/12/2022 15:24	11.26	15.5	SM3113B

Mark J. Riether, Lab Director

07/13/2022

Date

CHAIN OF CUSTODY RECORD

Customer: Larc School
Contact: Mark P Cheeseman
Address: 1089 Creek Road
 Bellmawr, NJ 08031
Phone:
Office:

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwaterest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection		Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
		Date	Time					
U120951	Field Blank	7/6/22	6:35	D	1 x 250	HNO3*	First Draw Lead	
U120952	Kit Sink Large		6:37	D	1 x 250	HNO3*	First Draw Lead	
U120953	Kit Sink Small		6:38	D	1 x 250	HNO3*	First Draw Lead	
U120954	Staff Lounge BR		6:40	D	1 x 250	HNO3*	First Draw Lead	
U120955	Staff Lounge Kitchen		6:39	D	1 x 250	HNO3*	First Draw Lead	
U120956	Cafe BR Women's Room		6:41	D	1 x 250	HNO3*	First Draw Lead	
U120957	Cafe BR Men's Room		6:42	D	1 x 250	HNO3*	First Draw Lead	
U120958	Office Sink - Main Office		6:43	D	1 x 250	HNO3*	First Draw Lead	
U120959	Office Sink BR - Main Office		6:44	D	1 x 250	HNO3*	First Draw Lead	
U120960	Nurse Office BR Sink		6:45	D	1 x 250	HNO3*	First Draw Lead	
U120961	Room 18 Sink		7:32	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SWSURFACE WATER WWWASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
<input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	* HNO3 preserved upon receipt at laboratory	°C
		Yes	No

Sampled by: *Kyle Quillen*
 (Print)

Sampled by/Relinquished by: _____
 (Signature)

Relinquished by: _____
 (Signature)

Relinquished by: _____
 (Signature)

Received by: _____ (Signature)	Date 7/6/22	Time 8:20
Received by: _____ (Signature)	Date	Time
Received by: _____ (Signature)	Date	Time

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Larc School
Contact: Mark P Cheeseman
Address: 1089 Creek Road
 Bellmawr, NJ 08031
Phone:
Office:

Lab ID#	Sample Location	Collection Date	Time	Grab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
V120962	Room 18 BR Sink	7/16/22	7:33	X		D	1 x 250	HNO3*	First Draw Lead	
V120963	Room 19 Sink		7:34	X		D	1 x 250	HNO3*	First Draw Lead	
V120964	Room 20 Sink		7:35	X		D	1 x 250	HNO3*	First Draw Lead	
V120965	Room 20 BR Sink		7:36	X		D	1 x 250	HNO3*	First Draw Lead	
V120966	Room 21 Sink		7:37	X		D	1 x 250	HNO3*	First Draw Lead	
V120967	Room 21 BR Sink		7:39	X		D	1 x 250	HNO3*	First Draw Lead	
V120968	Room 17 Sink		7:28	X		D	1 x 250	HNO3*	First Draw Lead	
V120969	Room 17 BR Sink		7:29	X		D	1 x 250	HNO3*	First Draw Lead	
V120970	Room 16 Sink		7:26	X		D	1 x 250	HNO3*	First Draw Lead	
V120971	Room 15 Sink		7:25	X		D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D/DIRINKING WATER A/AQUEOUS S/SOIL S/SLUDGE G/WG/GROUND WATER S/W/SURFACE WATER W/W/WASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp °C
	Yes		No

Sampled by: *Kyle Quillet*

Sampled by/Relinquished by: *[Signature]* Date: 7/16/22 8:20 Time: 0820

Relinquished by: *[Signature]* Date: Date Time: Time

Relinquished by: *[Signature]* Date: Date Time: Time

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Larc School
Contact: Mark P Cheeseman
Address: 1089 Creek Road
 Bellmawr, NJ 08031
Phone:
Office:

Lab ID#	Sample Location	Collection Date	Time	g	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
U120972	Room 14 Sink	7/6/22	7:23	X		D	1 x 250	HNO3*	First Draw Lead	
U120973	Room 14 BR		7:50	X		D	1 x 250	HNO3*	First Draw Lead	
U120974	New Nurse Office		7:30	X		D	1 x 250	HNO3*	First Draw Lead	
U120975	New Kitchen Sink 1		7:18	X		D	1 x 250	HNO3*	First Draw Lead	
U120976	New Kitchen Sink 2		7:19	X		D	1 x 250	HNO3*	First Draw Lead	
U120977	Room 13 Sink		7:15	X		D	1 x 250	HNO3*	First Draw Lead	
U120978	Room 12 Sink		7:14	X		D	1 x 250	HNO3*	First Draw Lead	
U120979	Room 11 Sink		7:13	X		D	1 x 250	HNO3*	First Draw Lead	
U120980	Room 10 Sink		7:11	X		D	1 x 250	HNO3*	First Draw Lead	
U120981	Room 9 Sink		7:10	X		D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D/DIRINKING WATER A/AQUEOUS S/SOIL S/SLUDGE G/W/GROUND WATER S/W/SURFACE WATER W/W/WASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp °C
	Yes	No	Properly Preserved

Sampled by: (Print) <u>Kyle Quill</u>	Date <u>7/6/22</u>	Time <u>8:20</u>	Received by: (Signature) <u>[Signature]</u>	Date <u>7-6-22</u>	Time <u>08:20</u>
Sampled by/Relinquished by: (Signature) <u>[Signature]</u>	Date _____	Time _____	Received by: (Signature) _____	Date _____	Time _____
Relinquished by: (Signature) _____	Date _____	Time _____	Received by: (Signature) _____	Date _____	Time _____

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Larc School
Contact: Mark P Cheeseman
Address: 1089 Creek Road
 Bellmawr, NJ 08031
Phone:
Office:

Lab ID#	Sample Location	Collection Date	Time	g	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
V120982	Room 8 Sink	7/6/22	7:01	X		D	1 x 250	HNO3*	First Draw Lead	
V120983	Room 7 Sink		7:02	X		D	1 x 250	HNO3*	First Draw Lead	
V120984	Room 6 Sink		6:59	X		D	1 x 250	HNO3*	First Draw Lead	
V120985	Room 5 Sink		7:00	X		D	1 x 250	HNO3*	First Draw Lead	
V120986	Room 4 Sink		6:58	X		D	1 x 250	HNO3*	First Draw Lead	
V120987	Room 3 Sink		6:56	X		D	1 x 250	HNO3*	First Draw Lead	
V120988	Room 2 Sink		6:51	X		D	1 x 250	HNO3*	First Draw Lead	
V120989	Room 1 Sink		6:49	X		D	1 x 250	HNO3*	First Draw Lead	
V120990	Room 1 BR Sink		6:40	X		D	1 x 250	HNO3*	First Draw Lead	
V120991	Room 2 BR Sink		6:52	X		D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SWS/SURFACE WATER WWW/WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
<input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	* HNO3 preserved upon receipt at laboratory	Properly Preserved No

Sampled by: (Print) <u>Kyle Quilich</u>	Received by: (Signature) <u>[Signature]</u>	Date <u>7/6/22</u>	Date <u>7/6/22</u>	Time <u>0820</u>	Time
Relinquished by: (Signature) <u>[Signature]</u>	Received by: (Signature) _____	Date 	Date 	Time 	Time
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date 	Date 	Time 	Time

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006

Customer: Larc School
Contact: Mark P Cheeseman
Address: 1089 Creek Road
 Bellmawr, NJ 08031
Phone:
Office:

Lab ID#	Sample Location	Collection Date	Time	g	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
V120992	Room 3 BR Sink	7/6/22	6:57	X		D	1 x 250	HNO3*	First Draw Lead	
V120993	Room 4 BR Sink		6:54	X		D	1 x 250	HNO3*	First Draw Lead	
V120994	Comp Room BR		6:47	X		D	1 x 250	HNO3*	First Draw Lead	
V120995	Hall BR Small		6:46	X		D	1 x 250	HNO3*	First Draw Lead	
V120996	Boys Room Sink		7:07	X		D	1 x 250	HNO3*	First Draw Lead	
V120997	Boys Room Sink		7:08	X		D	1 x 250	HNO3*	First Draw Lead	
V120998	Boys Room Sink		7:09	X		D	1 x 250	HNO3*	First Draw Lead	
V120999	Girls Room Sink		7:09	X		D	1 x 250	HNO3*	First Draw Lead	
V121000	Girls Room Sink		7:09	X		D	1 x 250	HNO3*	First Draw Lead	
V121001	Girls Room Sink		7:06	X		D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER A/AQUEOUS S/SOIL SL/SLUDGE GW/GROUND WATER S/SURFACE WATER W/WASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp °C
	Yes	No	Properly Preserved

Sampled by: *Kyle Quilley*

Sampled by/Relinquished by: *[Signature]* Date *7/6/22* Time *8:20*

Relinquished by: *[Signature]* Date _____ Time _____

Relinquished by: *[Signature]* Date _____ Time _____