



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Larc School
1089 Creek Road
Bellmawr, NJ 08031

Results of Lead Analysis

Sample ID:	Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
X148335	Field Blank	04/30/2025 06:11	05/1/2025 14:11	<2.00	15.5	SM3113B
X148336	Kit Sink Large	04/30/2025 06:12	05/5/2025 13:20	6.76	15.5	SM3113B
X148337	Kit Sink Small	04/30/2025 06:15	05/1/2025 14:24	4.38	15.5	SM3113B
X148338	Staff Lounge BR	04/30/2025 06:16	05/1/2025 14:30	<2.00	15.5	SM3113B
X148339	Staff Lounge Kitchen	04/30/2025 06:18	05/1/2025 14:37	<2.00	15.5	SM3113B
X148340	Cafe BR Womens Room	04/30/2025 06:19	05/5/2025 13:27	13.19	15.5	SM3113B
X148341	Cafe BR Mens Room	04/30/2025 06:20	05/5/2025 13:01	12.92	15.5	SM3113B
X148342	Office Sink Main Office	04/30/2025 06:21	05/5/2025 13:55	<2.00	15.5	SM3113B
X148343	Office Sink BR Main Office	04/30/2025 06:22	05/5/2025 13:39	<2.00	15.5	SM3113B
X148344	Nurses Office BR Sink	04/30/2025 06:24	05/5/2025 14:02	<2.00	15.5	SM3113B
X148345	Room 18 Sink	04/30/2025 07:02	05/5/2025 14:08	<2.00	15.5	SM3113B
X148346	Room 8 Sink	04/30/2025 06:40	05/6/2025 10:36	2.08	15.5	SM3113B
X148347	Room 7 Sink	04/30/2025 06:41	05/6/2025 10:42	<2.00	15.5	SM3113B
X148348	Room 6 Sink	04/30/2025 06:38	05/6/2025 10:55	<2.00	15.5	SM3113B
X148349	Room 5 Sink	04/30/2025 06:39	05/6/2025 11:02	<2.00	15.5	SM3113B
X148350	Room 4 Sink	04/30/2025 06:33	05/6/2025 11:08	12.31	15.5	SM3113B
X148351	Room 3 Sink	04/30/2025 06:35	05/6/2025 11:15	2.04	15.5	SM3113B
X148352	Room 2 Sink	04/30/2025 06:32	05/6/2025 11:34	6.94	15.5	SM3113B
X148353	Room 1 Sink	04/30/2025 06:28	05/6/2025 11:40	<2.00	15.5	SM3113B
X148354	Room 1 BR Sink	04/30/2025 06:29	05/6/2025 11:47	<2.00	15.5	SM3113B
X148355	Room 2 BR Sink	04/30/2025 06:31	05/6/2025 11:53	2.25	15.5	SM3113B
X148356	Room 3 BR Sink	04/30/2025 06:36	05/6/2025 12:00	<2.00	15.5	SM3113B
X148357	Room 4 BR Sink	04/30/2025 06:34	05/6/2025 12:06	3.20	15.5	SM3113B
X148358	Comp Room BR	04/30/2025 06:26	05/6/2025 12:12	3.06	15.5	SM3113B
X148359	Hall BR Small	04/30/2025 06:25	05/6/2025 10:17	5.67	15.5	SM3113B
X148360	Boys Room Sink	04/30/2025 06:46	05/6/2025 12:19	5.23	15.5	SM3113B
X148361	Boys Room Sink	04/30/2025 06:47	05/6/2025 12:25	<2.00	15.5	SM3113B
X148362	Boys Room Sink	04/30/2025 06:48	05/6/2025 12:32	<2.00	15.5	SM3113B
X148363	Girls Room Sink	04/30/2025 06:44	05/6/2025 13:10	5.04	15.5	SM3113B
X148364	Girls Room Sink	04/30/2025 06:45	05/6/2025 12:51	<2.00	15.5	SM3113B
X148365	Girls Room Sink	04/30/2025 06:43	05/6/2025 13:17	7.26	15.5	SM3113B
X148366	Room 14 Sink	04/30/2025 06:54	05/8/2025 10:46	3.83	15.5	SM3113B
X148367	Room 14 BR	04/30/2025 06:55	05/6/2025 13:29	3.09	15.5	SM3113B
X148368	New Nurse Office	04/30/2025 06:58	05/8/2025 12:03	3.04	15.5	SM3113B
X148369	New Kitchen Sink	04/30/2025 06:53	05/8/2025 12:09	<2.00	15.5	SM3113B
X148370	1New Kitchen Sink 2	04/30/2025 06:52	05/8/2025 12:16	<2.00	15.5	SM3113B
X148371	Room 13 Sink	04/30/2025 06:51	05/8/2025 12:22	<2.00	15.5	SM3113B

Units - ug/L = ppb



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Larc School
1089 Creek Road
Bellmawr, NJ 08031

Results of Lead Analysis

Sample ID:	Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
X148372	Room 12 Sink	04/30/2025 06:50	05/8/2025 12:29	3.79	15.5	SM3113B
X148373	Room 11 Sink	04/30/2025 06:49	05/8/2025 12:48	<2.00	15.5	SM3113B
X148374	Room 10 Sink	04/30/2025 06:48	05/8/2025 13:07	<2.00	15.5	SM3113B
X148375	Room 9 Sink	04/30/2025 06:42	05/8/2025 13:14	<2.00	15.5	SM3113B
X148376	Room 18 BR Sink	04/30/2025 07:03	05/8/2025 13:20	<2.00	15.5	SM3113B
X148377	Room 19 Sink	04/30/2025 07:04	05/8/2025 13:27	<2.00	15.5	SM3113B
X148378	Room 20 Sink	04/30/2025 07:07	05/8/2025 13:33	<2.00	15.5	SM3113B
X148379	Room 20 BR Sink	04/30/2025 07:08	05/8/2025 13:39	5.31	15.5	SM3113B
X148380	Room 21 Sink	04/30/2025 07:10	05/8/2025 13:46	4.37	15.5	SM3113B
X148381	Room 17 Sink	04/30/2025 06:59	05/8/2025 14:05	<2.00	15.5	SM3113B
X148382	Room 17 BR Sink	04/30/2025 07:00	05/8/2025 14:18	74.07	15.5	SM3113B
X148383	Room 16 Sink	04/30/2025 06:50	05/8/2025 14:25	<2.00	15.5	SM3113B
X148384	Room 15 Sink	04/30/2025 06:55	05/8/2025 14:31	<2.00	15.5	SM3113B

Mark J. Riether, Lab Director

05/09/2025

Date

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006



Customer:	Larc School
Contact	Mark P Cheeseman
Address:	1089 Creek Road Bellmawr, NJ 08031
Phone:	
Office:	Fax:

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
X148335	Field Blank	4/30/25	611	D	1 x 250	HNO3*	First Draw Lead	
X148336	Kit Sink Large		612	D	1 x 250	HNO3*	First Draw Lead	
X148337	Kit Sink Small		615	D	1 x 250	HNO3*	First Draw Lead	
X148338	Staff Lounge BR		616	D	1 x 250	HNO3*	First Draw Lead	
X148339	Staff Lounge Kitchen		618	D	1 x 250	HNO3*	First Draw Lead	
X148340	Cafe BR Women's Room		619	D	1 x 250	HNO3*	First Draw Lead	
X148341	Cafe BR Men's Room		620	D	1 x 250	HNO3*	First Draw Lead	
X148342	Office Sink -, Main Office		621	D	1 x 250	HNO3*	First Draw Lead	
X148343	Office Sink BR - Main Office		622	D	1 x 250	HNO3*	First Draw Lead	
X148344	Nurse Office BR Sink		624	D	1 x 250	HNO3*	First Draw Lead	
X148345	Room 18 Sink		702	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AIAQUEOUS SISOIL SLISLUDGE GWGGROUND WATER SWSURFACE WATER WWWASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard ☐ NJ DEP Reduced Deliverables ☐ NJ DEP Full Deliverables ☐ Electronic Data Deliverables ☐ PWTA Format		Comments/Special Instructions * HNO3 preserved upon receipt at laboratory		Cooler Temp °C 22.0
					Properly Preserved Yes ☒ No ☐

Sampled by: (Print) Christopher Wright	Received by: (Signature) [Signature]	Date 4/30/25	Time 1500
Sampled by/Relinquished by: (Signature) [Signature]	Received by: (Signature) [Signature]	Date 4/30/25	Time 1500
Relinquished by: (Signature) [Signature]	Received by: (Signature) [Signature]	Date 4/30/25	Time 1500
Relinquished by: (Signature) [Signature]	Received by: (Signature) [Signature]	Date 4/30/25	Time 1500

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC

4077 South Black Horse Pike

Williamstown, NJ 08094

Phone: 856-875-3506 Fax: 856-875-3507

www.sjwatertest.com

NJ DEP Certification #08006

Customer:	Larc School
Contact	Mark P Cheeseman
Address:	1089 Creek Road Bellmawr, NJ 08031
Phone:	
Office:	

Lab ID#	Sample Location	Collection Date	Time	Lab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
X148346	Room 8 Sink	4/30/25	640	X		D	1 x 250	HNO3*	First Draw Lead	
X148347	Room 7 Sink		641	X		D	1 x 250	HNO3*	First Draw Lead	
X148348	Room 6 Sink		638	X		D	1 x 250	HNO3*	First Draw Lead	
X148349	Room 5 Sink		639	X		D	1 x 250	HNO3*	First Draw Lead	
X148350	Room 4 Sink		633	X		D	1 x 250	HNO3*	First Draw Lead	
X148351	Room 3 Sink		635	X		D	1 x 250	HNO3*	First Draw Lead	
X148352	Room 2 Sink		632	X		D	1 x 250	HNO3*	First Draw Lead	
X148353	Room 1 Sink		628	X		D	1 x 250	HNO3*	First Draw Lead	
X148354	Room 1 BR Sink		629	X		D	1 x 250	HNO3*	First Draw Lead	
X148355	Room 2 BR Sink		631	X		D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D\DRINKING WATER A\AQUEOUS S\SOIL SL\SLUDGE GW\GROUND WATER SW\SURFACE WATER WW\WASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard ___ NJ DEP Reduced Deliverables ___ NJ DEP Full Deliverables ___ Electronic Data Deliverables ___ PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp Iced °C
			Properly Preserved Yes
			No

Sampled by: (Print) <i>Christophe White</i>	Date 4/30/25	Time 1500	Received by: (Signature) <i>[Signature]</i>	Date 4/30/25	Time 12:20
Sampled by/Relinquished by: (Signature) <i>[Signature]</i>	Date	Time	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Date	Time	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Date	Time	Received by: (Signature)	Date	Time

CHAIN OF CUSTODY RECORD

Customer:	Larc School
Contact:	Mark P Cheeseman
Address:	1089 Creek Road Bellmawr, NJ 08031
Phone:	Fax:
Office:	

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwaterfertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
X148350	Room 3 BR Sink	4/30/25	636	D	1 x 250	HNO3*	First Draw Lead	
X148351	Room 4 BR Sink		634	D	1 x 250	HNO3*	First Draw Lead	
X148352	Comp Room BR		626	D	1 x 250	HNO3*	First Draw Lead	
X148353	Hall BR Small		625	D	1 x 250	HNO3*	First Draw Lead	
X148354	Boys Room Sink		646	D	1 x 250	HNO3*	First Draw Lead	
X148355	Boys Room Sink		647	D	1 x 250	HNO3*	First Draw Lead	
X148356	Boys Room Sink		648	D	1 x 250	HNO3*	First Draw Lead	
X148357	Girls Room Sink		644	D	1 x 250	HNO3*	First Draw Lead	
X148358	Girls Room Sink		645	D	1 x 250	HNO3*	First Draw Lead	
X148359	Girls Room Sink		643	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS S\SOIL SL\SLUDGE GW\GROUND WATER SWS\SURFACE WATER WWW\WASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard _____ NJ DEP Reduced Deliverables _____ NJ DEP Full Deliverables _____ Electronic Data Deliverables _____ PWTA Format _____	Comments/Special Instructions _____ * HNO3 preserved upon receipt at laboratory Yes ☒ No ☐	Cooler Temp Ice <u>12</u> °C Properly Preserved

Sampled by: (Print) <u>Christopher L. White</u>	Date <u>4/30/25</u>	Time <u>1500</u>	Received by: (Signature) <u>[Signature]</u>	Date <u>4/30/25</u>	Time <u>1520</u>
Sampled by/Relinquished by: (Signature) <u>[Signature]</u>	Date <u>4/30/25</u>	Time <u>1500</u>	Received by: (Signature) <u>[Signature]</u>	Date <u>4/30/25</u>	Time <u>1520</u>
Relinquished by: (Signature) <u>[Signature]</u>	Date <u>4/30/25</u>	Time <u>1500</u>	Received by: (Signature) <u>[Signature]</u>	Date <u>4/30/25</u>	Time <u>1520</u>
Relinquished by: (Signature) <u>[Signature]</u>	Date <u>4/30/25</u>	Time <u>1500</u>	Received by: (Signature) <u>[Signature]</u>	Date <u>4/30/25</u>	Time <u>1520</u>

CHAIN OF CUSTODY RECORD

Customer:	Larc School
Contact	Mark P Cheeseman
Address:	1089 Creek Road Bellmawr, NJ 08031
Phone:	Fax:
Office:	

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwaterest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
X148340	Room 14 Sink	4/30/15	654	D	1 x 250	HNO3*	First Draw Lead	
X1483407	Room 14 BR		655	D	1 x 250	HNO3*	First Draw Lead	
X1483408	New Nurse Office		658	D	1 x 250	HNO3*	First Draw Lead	
X1483409	New Kitchen Sink 1		653	D	1 x 250	HNO3*	First Draw Lead	
X148370	New Kitchen Sink 2		652	D	1 x 250	HNO3*	First Draw Lead	
X148371	Room 13 Sink		651	D	1 x 250	HNO3*	First Draw Lead	
X148372	Room 12 Sink		650	D	1 x 250	HNO3*	First Draw Lead	
X148373	Room 11 Sink		649	D	1 x 250	HNO3*	First Draw Lead	
X148374	Room 10 Sink		648	D	1 x 250	HNO3*	First Draw Lead	
X148375	Room 9 Sink		647	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GWAGROUND WATER SWSURFACE WATER WWWASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp 72°F Properly Preserved Yes

Sampled by: (Print) Christopher Labright	Date 4/30/15	Time 1500	Received by: (Signature)	Date 4/30/15	Time 1500
Sampled by/Relinquished by: (Signature)			Received by: (Signature)		
Relinquished by: (Signature)			Received by: (Signature)		
Relinquished by: (Signature)			Received by: (Signature)		

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006

Customer:	Larc School
Contact	Mark P Cheeseman
Address:	1089 Creek Road Bellmawr, NJ 08031
Phone:	Fax:
Office:	

Lab ID#	Sample Location	Collection Date	Time	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
X148376	Room 18 BR Sink	4/30/25	703	X	D	1 x 250	HNO3*	First Draw Lead	
X148377	Room 19 Sink		704	X	D	1 x 250	HNO3*	First Draw Lead	
X148378	Room 20 Sink		707	X	D	1 x 250	HNO3*	First Draw Lead	
X148379	Room 20 BR Sink		708	X	D	1 x 250	HNO3*	First Draw Lead	
X148380	Room 21 Sink		710	X	D	1 x 250	HNO3*	First Draw Lead	
X148381	Room 21 BR Sink			X	D	1 x 250	HNO3*	First Draw Lead	
X148382	Room 17 Sink		659	X	D	1 x 250	HNO3*	First Draw Lead	
X148383	Room 17 BR Sink		700	X	D	1 x 250	HNO3*	First Draw Lead	
X148384	Room 16 Sink		657	X	D	1 x 250	HNO3*	First Draw Lead	
X148385	Room 15 Sink		658	X	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D|DRINKING WATER A|AQUEOUS S|SOIL SL|SLUDGE GW|GROUND WATER SW|SURFACE WATER WW|WASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval	Report Format Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp Iced Properly Preserved Yes No
---	---	--	---

Sampled by: (Print) Christopher Wright	Date 4/30/25	Time 1500
Sampled by/Relinquished by: (Signature) [Signature]	Received by: (Signature) [Signature]	Date 4/30/25
Relinquished by: (Signature) [Signature]	Received by: (Signature) [Signature]	Date [Date]
Relinquished by: (Signature) [Signature]	Received by: (Signature) [Signature]	Date [Date]